

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
Mr. Johannes Berthel
Hiltistraße 6
86916 Kaufering

Dear Mr. Berthel,

representatively for the product **CFS-P BA – Firestop Putty Bandage** manufactured by **Hilti Entwicklungsgesellschaft mbH**, the materials listed under the overview of samples in the test reports no. 58011-A001-CS-L and 58011-A001-L dated 2023-03-01 were examined in the laboratory. The testing results comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))
- VOC content ASTM D 2369 – 20 and South Coast Air Quality Management District (SCAQMD) Rule 1168

These criteria meet the requirements for low-emitting **Adhesives and Sealants** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario	Individual VOCs of Concern		Formaldehyde		TVOC
	Requirement	Requirement hold	Requirement	Requirement hold	Range
School Classroom	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³
Private Office	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³

Mass per surface area: not applicable

VOC content	VOC Limit Value*
12.18 g/L	50 g/L

* VOC Limit Value for "All Other Architectural Sealants" (SCAQMD 1168, 10/2017)

Cologne, 2023-03-30



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project manager)